

SCS Global Services does hereby certify that an independent assessment has been conducted on behalf of:

# Novalis US, LLC

Novalis Innovative Flooring, No. 23 Shengyuan Road, Dantu District, Zhenjiang City, Jiangsu

For the following product(s):

**AVA Vinyl Tile:**

AVA 12, AVA 25MPL, AVA 2DSGN, AVA 2SPRK, AVA 2STYL, AVA CLSC, AVA DAZL, AVA DSGN, AVA MRGE, AVA RSRV, AVA RYME, AVA RYME+, AVA SMPL, AVA SNSE, AVA SPRK, AVA STRM, AVA STYL, AVA VRSE

The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):

**Indoor Advantage™ Gold**

Indoor Air Quality Certified to SCS-EC10.3-2014 v4.0

Conforms to the CDPH/EHLB Standard Method (CA 01350) v1.2-2017 for the private office, school classroom, and single-family residence parameters<sup>1</sup>.

<sup>1</sup> Modeled As Flooring

Measured Concentration of TVOC: Less than/equal to 0.5 mg/m<sup>3</sup> (in compliance with CDPH/EHLB Standard Method v1.2 -2017)

Registration # SCS-IAQ-05370

Valid from: May 1, 2021 to April 30, 2022



A handwritten signature in black ink that reads "Stanley Mathuram".

Stanley Mathuram, PE, Vice President  
SCS Global Services  
2000 Powell Street, Ste. 600, Emeryville, CA 94608 USA